



FORMATURA  
INIEZIONE  
POLIMERI

**CERTIFICATE** (According to EN 10204.3.1B)

**1 - PRODUCT: PVC SEDIMENT STRAINER**

**2 - MANUFACTURER: FIP SpA**

Quality System certified acc. to EN-ISO 9001:2000 by SQP/IIP (IQNET)

**3 - RAW MATERIAL SPECIFICATION**

The sediment strainer are manufactured out of PVC-U compound without the use of plasticizer and fillers.

The PVC-U compound is in accordance with the Italian Health Bulletin "Circolare Ministeriale" n. 102/1978 and the Ministerial Decree dtd 21.03.73 concerning health aspects of plastics with respect to potable water and foodstuff applications.

**4 - MANUFACTURING CONTROL**

**4.1 DIMENSIONS**

The dimensions of sediment strainer correspond to: DIN 8063, ISO 4422 part 3, EN 1452 part 3, NPT 54028, EN ISO 15493.

**4.2 VISUAL INSPECTION**

The sediment strainer are certified to be free of bubbles, blisters, scratches or other faults detrimental to the product performance.

**4.3 TESTS**

The sediment strainer are tested according to ISO 9393.

**5 - PERFORMANCES**

The applicable PN is stated in FIP Technical Catalogue; in general: PN 16 for d.20-32, PN 10 d.40-75, PN 6 d.90-110.

**6 - PACKAGING**

The products are packaged in cartons or other boxes, in order to avoid any damage during handling and transportation and from ultra violet rays.

Signature

  
F.I.P. Formatura Iniezione Polimeri Spa

Formatura Iniezione Polimeri s.p.a.

Direzione Generale, Sede Legale e Stabilimento

Località Pian di Parata 16015 Casella (GE) Italy Tel. +39 010.9621.1 Fax +39 010.9621.209 E-mail: info@fipnet.it Web: www.fipnet.it

Ufficio vendite e depositi Milano Tel +39 02.9390.1217 - Fax +39 02.9390.1207

Cap. Soc.: € 6.200.000 C.F. 00276860103 C.C.I.A.A. Genova: 196879 N. 27325 Reg. Imp. Canc. Trib. GE

