



ATT.NE Mr. JOSEP TAMBOLEO

**CERTIFICATE** (According to EN 10204-3.1B)

**1 - PRODUCT: PPH VALVES**

**2 - MANUFACTURER: FIP SpA**

Quality System certified acc. to EN-ISO 9002 by SQP/IIP (IQNET)

**3 - RAW MATERIAL SPECIFICATION**

The PPH valves are manufactured out of stabilized Polypropylene Homo-polymer.

The PPH compound is in accordance with the Italian Ministerial Decree dtd 21.03.73 concerning health aspects of plastics with respect to foodstuff applications.

**4 - MANUFACTURING CONTROL**

**4.1 DIMENSIONS**

The dimensions of valves correspond to: DIN 3432 sheet 2-3, DIN 3202 ISO 8442.

**4.2 VISUAL INSPECTION**

The valves are certified to be free of bubbles, blisters, scratches or other faults detrimental to the product performance.

**4.3 TESTS**

The valves are tested according to ISO 9393 - DIN 3442 sheet 1.

**5 - PERFORMANCES**

The applicable PN is stated in FIP Technical Catalogue; in general:

Ball valves PN 10 for d 20-90, PN 6 for d 110

Diaphragm valves PN 10 for d 20-110

Butterfly valves PN 10 for d.90-280, PN 8 for d.315.

Ball check valve PN 10 for d.20-63.

**6 - PACKAGING**

The products are packaged in cartons or other boxes, in order to avoid any damage during handling and transportation and from ultra violet rays.

Signature  F.I.P. Formatura Iniezione Polimeri Spa

Formatura Iniezione Polimeri s.p.a.

Direzione Generale, Sede Legale e Stabilimento

Località Pian di Parata 16015 Casella (GE) Italy Tel. +39 010.9621.1 Fax +39 010.9621.209 E-mail: info@fipnet.it Web: www.fipnet.it

Ufficio vendite e depositi Milano Tel +39 02.9390.1217 - Fax +39 02.9390.1207

Cap. Soc.: € 6.200.000 C.F. 00276860103 C.C.I.A.A. Genova: 196879 N. 27325 Reg. Imp. Canc. Trib. GE

