



CERTIFICATE (According to EN 10204.3.1B)

- 1 - PRODUCT: PVC-U VALVES**
2 - MANUFACTURER: FIP SpA

Quality System certified acc. to EN-ISO 9001:2000 by SQP/IIP (IQNET)

3 - RAW MATERIAL SPECIFICATION

The valves are manufactured out of PVC-U compound without the use of plasticizer and fillers.

The PVC-U compound is in accordance with the Italian Health Bulletin "Circolare Ministeriale" n. 102/1978 and the Ministerial Decree dtd 21.03.73 concerning health aspects of plastics with respect to potable water and foodstuff applications.

4 - MANUFACTURING CONTROL

4.1 DIMENSIONS

The dimensions of valves correspond to: DIN 3441 sheet 2-3-4-5 ISO 4422 part 4 - EN 1452 part 4 -ISO 727.

4.2 VISUAL INSPECTION

The valves are certified to be free of bubbles, blisters, scratches or other faults detrimental to the product performance.

4.3 TESTS

The valves are tested according to EN 1452 part 4 -ISO 9393 - DIN 3441 sheet 1.

5 - PERFORMANCES

The applicable PN is stated in FIP Technical Catalogue; in general:
Ball valves PN 16 for d 16-63, PN 10 for d.75-110, PN 6 VX-VE d.110,
Diaphragm valves PN 10 for d 20-110

Butterfly valves PN 10 for d 90-280, PN 8 d.315.

Ball check valve PN 16 for d 20-63

3 ways valves PN 10 for d 20-63

Angle seat valves and check valves PN 16 for d 16-32, PN 10 for d 40-75, PN 6 for d 90-110.

Pneumatically actuated ball valves (3 ways) PN 6 for d 20-63.

Air release valves PN 16 for d.20-63.

6 - PACKAGING

The products are packaged in cartons or other boxes, in order to avoid any damage during handling and transportation and from ultra violet rays.

Signature  F.I.P. Formatura Iniezione Polimeri Sga

Formatura Iniezione Polimeri s.p.a.

Direzione Generale, Sede Legale e Stabilimento

Località Pian di Parata 16015 Caselle (GE) Italy Tel. +39 010.9621.1 Fax +39 010.9621.209 E-mail: info@fipnet.it Web: www.fipnet.it

Ufficio vendite e depositi Milano Tel +39 02.9390.1217 - Fax +39 02.9390.1207

Cap. Soc.: € 6.200.000 C.F. 00276860103 C.C.I.A.A. Genova: 198879 N. 27325 Reg. Imp. Canc. Trib. GE

