



CERTIFICATE (According to EN 10204-3.1B)

1 - PRODUCT: PVDF VALVES

2 - MANUFACTURER: FIP SpA

Quality System certified acc. to EN-ISO 9002 by SQP/IIP (IQNET)

3 - RAW MATERIAL SPECIFICATION

The valves are manufactured out of PVDF compound.
The PVDF raw material is in accordance with " Food and Drug Administration" USA requirements for foodstuff applications and it has been tested by Hygiene Istitut des Ruhrgebiets zu Gelsenkirchen, following KTW recommendations, for transportation of cold and hot water intended for human consumption.

4 - MANUFACTURING CONTROL

4.1 DIMENSIONS

The dimensions of the valves correspond to: ISO-DIS 10931 part 4.

4.2 VISUAL INSPECTION

The valves are certified to be free of bubbles, blisters, scratches or other faults detrimental to the product performance.

4.3 TESTS

The valves are tested according to ISO 9393 - DIN 3442 sheet 1.

5 - PERFORMANCES

The applicable PN is stated in FIP Technical Catalogue; in general:
Ball valves PN 16 for d.20-63, PN 10 for d.75-90.

Diaphragm valves PN 10 for d.20-110.

Butterfly valves PN 10 for d. 75-280, PN 8 for D.315.

6 - PACKAGING

The products are packaged in cartons or other boxes, in order to avoid any damage during handling and transportation and from ultra violet rays.

Signature


F.I.P. Formatura Iniezione Polimeri SpA

Formatura Iniezione Polimeri s.p.a.

Direzione Generale, Sede Legale e Stabilimento

Località Pian di Pereta 16015 Casella (GE) Italy Tel. +39 010.9621.1 Fax +39 010.9621.209 E-mail: info@fipnet.it Web: www.fipnet.it

Ufficio vendite e depositi Milano Tel +39 02.9390.1217 - Fax +39 02.9390.1207

Cap. Soc.: € 6.200.000 C.F. 00276860105 C.C.I.A.A. Genova: 196879 N. 27325 Reg. Imp. Canc. Trib. GE

